



PAVUS, a.s.
Notified Body No. 1391
Prosecká 412/74, 190 00 Praha 9 - Prosek
Decision No. 27/2013-CPR of 13. 12. 2013

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1391-CPR-0090/2014

In compliance with Regulation 305/2011/EU of European Parliament and of the Council of 9 March 2011 (the Construction Product regulation or CPR), this certificate applies to the construction product:

Fire damper FDMC

Technical parameters of the product:
are stated in the Annex No. 1 of this Certificate of constancy of performance

Intended use of the product in buildings:

Fire dampers are used in conjunction with partitions to maintain fire compartments and protect means of escape in case of fire in heating, ventilation and air conditioning (HVAC) systems in buildings, under methods of use and installation conditions stated in Certification report and related documentation. All fire dampers close automatically in response to raised temperatures indicating fire.

produced by or for:

MANDÍK, a.s.
Dobříšská 550, 267 24 Hostomice, Czech republic, IdNo. 26718405

and produced in the manufacturing plant:

MANDÍK, a.s.
Dobříšská 550, 267 24 Hostomice, Czech republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:


EN 15650:2010

**under system 1 for the performances set out in this certificate are applied and that
the construction product fulfils all the prescribed requirements for these
performances**

This certificate was first issued on 29th August 2012 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body. This Certificate replaces and cancels ES certificate of conformity No. 1391-CPD-0134/2012 of 29th August 2012 issued by NB 1391.

In Prague 28th July 2014




Ing. Jaroslav Dufek
Managing Director PAVUS, a.s.

Technical parametres of the product *)

- External dimension of the element: min. diameter 100 mm, max. 400 mm
- Construction length: min. 420 mm, max. 500 mm
- Starting devices and drives:
 - fuse safety lock 72°C/95°C/104°C/147°C with closing spring
 - pulse magnetic drive
 - Bellimo - spring drive with starting device 72°C/95°C
 - Gruner - spring drive with starting device 72°C/95°C
 - Schischek - spring drive with starting device 72°C/95°C
 All used marks of drives fulfil 10 000 cycles according to EN 15650.
- Material versions:
 - galvanized sheet metal,
 - stainless sheet metal,
 - painted sheet metal.
- Leak tightness of the damper according to EN 1751:
 - over blade class 3 (Ø 200 - 400 mm), 2 (Ø 180 mm) and 1 (Ø 100 - 160 mm)
 - over case min. class C

The classification according to EN 13501-3:2005+A1:2009:

EI 60 (ve ho i↔o) S

Assessed properties of the product

Essential characteristics	Requirement clauses in EN 15650	Requirement	Conformity Assessment
Nominal activation conditions/sensitivity:	4.2.1.2	EN 15650, 4.2.1.2	conforms
- sensing element load bearing capacity	4.2.1.2.2	EN 15650, 5.2.5	conforms
- sensing element response temperature	4.2.1.2.3	EN 15650, 5.2.5	conforms
Response delay (response time):			
- closure time	4.2.1.3	EN 1366-2, 10.4.6	conforms
Operational reliability:			
- cycling	4.3.1, a)	The fire damper conforms to cycle test if 50 cycles are done prior to the fire test	conforms
Fire resistance			
- integrity	4.1.1, a)	E	conforms
- insulation	4.1.1, b)	EI	conforms
- smoke leakage	4.1.1, c)	ES/EIS	conforms
- mechanical stability (under E)	4.1.1, a)	-	conforms
- maintenance of the cross section (under E)	4.1.1, a)	-	conforms
Durability of response delay:			
- sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	EN 15650, 4.2.1.2	conforms
Durability of operational reliability:			
- open and closing cycle tests	4.3.3.2	EN 15650, Annex C.3.2	conforms
Resistance against corrosion	4.2.2 Annex B	Increased resistance against corrosion - Salt spray exposure test (EN 60068-2-52)	conforms

*) Detailed technical parametres and conditions of final classification according to EN 13501-3:2005+A1:2009 are stated in the Certification Report No. P-1391-CPR-0090/2014 of 28th July 2014.

Fire damper FDMC may be produced and placed on the market also with trade name BSK-C-60-R.

CE
1391
MANDÍK a.s., Dobříšská 550, 267 24 Hostomice, Czech rep. 14 1391 – CPR - 0090/2014
EN 15650 Fire damper type/model: Fire damper FDMC
Classification EI 60 (ve ho i↔o) S



[Signature]
Ing. Jaroslav Dufek
Managing Director PAVUS, a.s.
Notified Body No.1391